

VILLAGE OF JOHNSTOWN, OHIO

Village of Johnstown
Administrative Offices
www.johnstownohio.org



599 S. Main Street
PO Box 457
Johnstown, Ohio 43081
Telephone: 740-967-1139
Fax: 740-967-3519

Division of Water and Sewage

DEDUCT METER POLICY

1. All deduct meters will be permanently installed and used for that location only.
2. Water customer agrees to install and maintain an approved backflow prevention device to protect the public water supply. An approved backflow prevention device is a testable double check valve that conforms to one of the following standards: ANSI/AWWA C510-97, ASSE 1015-99, or CSA B64.5-01 (2001). If there is any question whether a particular device is acceptable, please contact the water department. Typical cost for a 3/4" device is \$200.00.
3. Water customer agrees to install and maintain a deduct meter.
4. Backflow prevention device will require an initial inspection at time of installation and an annual inspection by a state certified inspector to be paid for by the customer. Typical cost for initial inspection is \$125.00.
5. Installation of deduct meter will require an initial inspection at time of installation and an annual inspection by the Village Water Department. The annual inspection fee is \$35.00
6. Deduct meter will be installed to meter only water that will not enter into the sanitary sewer system.
7. Deduct meter will be read at the same time as the primary water meter serving that location.
8. Customer will receive a sewer credit based on the deduct meter reading on the regular monthly billing for water and sewer usage.
9. Customer will be charged an annual fee, as established by the Village Manager, for the inspection reading, and calculation of sewer credit of the deduct meter. The annual fee is \$10.00.
10. Water department personnel shall have access to the deduct meter for the purpose of inspection at all reasonable times.
11. The Village Manager may disallow the use of the deduct meter if any of the above requirements are violated or if misuse of improper use are detected.